



- NOTE:
IF HAVE TO RELOCATED ANY
ELECTRIC FIRE ALARM SOUND,
THE SHOP-DRAWINGS FOR IT
WILL BE PROVIDED.

EXISTING TO REMAIN MAIN BREAKER = 200 AMPS

<u>SCOPE OF WORK</u>	<u>ELECTRICAL</u>
<u>INTERIOR REMODELING & ALTERATION LEVEL II</u>	
<u>FLORIDA BUILDING CODE 2020 7th. EDITION</u>	<u>NEC 2017</u>

- EXISTING ELECTRIC PANEL REMAIN THE SAME. ONLY ADDED TWO(2) BREAKERS (32- 33) FOR CURTAINS RECEPTACLES AS SHOWN.
- REPLACE OR RELOCATED KITCHEN APPLIANCES HAS A NEW POWER OUTLETS AS SHOWN ON PLAN.
- EXISTING SMALL APPLIANCES CIRCUITS WILL BE RELOCATED AS PER PLAN.
- REPLACED AND RELOCATED WASHER & DRYER HAS A NEW POWER OUTLETS AS SHOWN ON PLAN.
- NOT ANY APPLIANCE LOAD HAS BEEN ADDED.
- ALL LIGHTINGS WILL BE LED AND LOW CONSUMER.
- ALL NEW LIGHTINGS WILL BE CONNECTED TO EXISTING CIRCUIT IN EACH AREA AS SHOWN ON PLAN.
- RECEPTACLES WILL BE NEW, RELOCATED AND/OR RENOVATED (TAMPER RESISTANT).

GEORGE FREIJO, P.E.
REGISTERED ENGINEER NO. 32578
STATE OF FLORIDA CA#: 29796